FIRE SAFETY CERTIFICATE

Ref. No.- FIRE /48/2025

Date: 21 04 2025

1. As Per B Form Fire Fighting 875 tem 15 go

2 Condition

3.

Issued on 2 04 2025 At Kolhapur (place) by Strike out whichever is not applicable

Signature with Seal

Name

Designation

esignation

Chief Fire Officer

Name & Address of Department/ Office : Kolhapur Municipal Corporation

To

Sangli Mission Society's Alphonsa School P.B.No.7, Bhosale Vasti, Jath P O, Sangli (Dist), Mharashtra-416404

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language ,translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



(Govt. Approved Agency)

HREE MAHALAXMI **IRE & SAFETY SERVICES**

Fire Fighting Equipment of Sales & Services, Hydrant, Sprinkler & Suppression System Installation Work, Design & Consulting (E-mail: smfiresafety27@gmail.com)

1243/77, 'E' Ward, Shivaji Udyam Nagar, Kolhapur- 416 008. Mob.: 9960045003, 8888926333, 8087701425

Ref No.: B/242504/063

Date: 21.04.2025

(Government Approved License Agency) License No: MFS-LA/RF-240, RD-221

FORM-B

(see section 3 (3) and rule 4(2) Six monthly certification to be given in every January and July by the occupier for compliance of the fire prevention and life safety measures.

CERTIFICATE

Certified that we have carried out inspection of fire prevention & Life Safety Measures installed in the following building or premises namely.

(Building Numbers, colony Name & Address)

SANGLI MISSION SOCIETYS ALPHONSA SCHOOL Jath, Tal. Sangli-416404

We further certify that these installation in the above mentioned building are maintained in good repair and efficient condition during the period July 2024 to Dec 2024, as required under the provision of the Maharashtra Fire Prevention & Life Safety Measure Act. 2006 (Mah-III of 2007). The detail of the inspection & maintenance of installation carried out by us are mentioned in the report appended herewith.

Place: Kolhapur



d Saradar / Mulla

Mahamma Digitally signed by Mahammad Saradar Mulla Date: 2025.04.21 11:46:59 +05'30'



(Govt. Approved Agency)

E MAHALAXMI & SAFETY SERVICES

Fire Fighting Equipment of Sales & Services, Hydrant, Sprinkler & Suppression System Installation Work, Design & Consulting (E-mail: smfiresafety27@gmail.com)

1243/77, 'E' Ward, Shivaji Udyam Nagar, Kolhapur- 416 008. Mob.: 9960045003, 8888926333, 8087701425

.... 2

(Government Approved License Agency) License No: MFS-LA/RF-240, RD-221

SANGLI MISSION SOCIETYS ALPHONSA SCHOOL Jath, Tal. Sangli-416404

SR. NO	DESCRIPTION	QTY.	REMARK
1	Pump Set , Wilo Make 2 HP	01 Nos	OK
2	GI Pipe B Class 4" (24 Mtr.) & 3" (14 Mtr.) With fitting Materials	38 Mtr	OK
3	Hydrant Valve SS ISI Mark	06 Nos	OK
4	Hose Real Drum	06 Nos	OK
5	Two way (Fire Brigade Connection)	01 Nos	OK
6	RRL Hose Pipe with Male Female Coupling	01 Nos	OK
7	SS Branch Nozzle	01 Nos	OK
8	Hose Box	01 Nos	OK
9	Fire Alarm System -(Hooter-3, MCP-3, Panel-1)	01 Set	OK
10	ABC Type Fire Extingisher-06 Kg	06 Nos	OK



d Saradar/ Mulla

Mahamma Digitally signed by Mahammad Saradar Mulla Date: 2025.04.21

11:47:18 +05'30'